

# Certificate of Compliance

Certificate Number **20090331, E328874**  
Report Reference **E328874, 2009 March 24**  
Issue Date **2009 March 31**

Page 1 of 2



*Issued to:* **I C E SRL**  
ZONA INDUSTRIALE REMARTELLO 22  
65014 LORETO APRUTINO PE ITALY

*This is to certify that  
representative samples of*


**Systems, Electrical Insulation - Component**  
Systems, Electrical Insulation

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* **UL 1446 Systems of Insulating Materials - General**

*Additional Information:* **See Addendum for Ratings**

**Only those products bearing the UL Recognized Component Mark should be considered as being covered by UL's Recognition and Follow-Up Service.**

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions.

**Look for the UL Recognized Component Mark on the product**

Issued by:  
**Rita Chiodini, Project Engineer**  
Underwriters Laboratories Inc.

Reviewed by:  
**Mark Raymond, Lead Engineering Assoc**  
Underwriters Laboratories Inc.

# Certificate of Compliance

Certificate Number **20090331, E328874**  
Report Reference **E328874, 2009 March 24**  
Issue Date **2009 March 31**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## RATINGS:

System Designation	Insulation Class	Maximum Hot Spot Temperature
ICE130-1	130(B)	130

System Designation	Indoor	Outdoor (Enclosed)
ICE130-1	Yes	Yes

Issued by:  
**Rita Chiodini, Project Engineer**  
Underwriters Laboratories Inc.

Reviewed by:  
**Mark Raymond, Lead Engineering Assoc**  
Underwriters Laboratories Inc.